


**Bateman Engineering**

|              |                                      |              |            |
|--------------|--------------------------------------|--------------|------------|
| Project      | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No.  |                                      | Design Date  | 23/01/2016 |
| Category     | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Network Type | Liquid                               | Calc. Method | Darcy      |
| Description  | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

Copper Mine and Solvent Solution Process Plant Water Supply system.  
This is an existing mine and township water supply system including a river extraction pump, open pit dewatering system, process plant feed, township resevoir and overhead tank supply system.

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |



MICCL Water Supply PS1-PS3 Upgrade 2

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 5                                    | From node to node   | 0 - 1             |
| Description       | Pump Discharge                       | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 020           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 206.4 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 1.9 m             |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 2500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 4.2                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 566.99 m3/hr                         | Velocity            | 4.71 m/s          |
| Friction Loss     | 0.16 m                               | Fitting Losses      | 4.74 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 4.9 m                                | Total Pressure Drop | 48.06 kPa         |
| Entry Total Head  | 86.07 m                              | Exit Total Head     | 81.17 m           |
| Entry Gauge Head  | 12.07 m                              | Exit Gauge Head     | 16.17 m           |
| Reynolds No.      | 961947.62                            | Friction Factor     | 0.01491 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 6                                    | From node to node   | 1 - 2             |
| Description       | Pontoon discharge                    | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 020           |
| Nominal Diameter  | 300 mm                               | Inside Diameter     | 311.2 mm          |
| Outside Diameter  | 323.9 mm                             | Pipe Length         | 6 m               |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 4500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0.72                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 566.99 m3/hr                         | Velocity            | 2.07 m/s          |
| Friction Loss     | 0.06 m                               | Fitting Losses      | 0.16 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.22 m                               | Total Pressure Drop | 2.15 kPa          |
| Entry Total Head  | 81.17 m                              | Exit Total Head     | 80.95 m           |
| Entry Gauge Head  | 16.17 m                              | Exit Gauge Head     | 10.95 m           |
| Reynolds No.      | 638001.25                            | Friction Factor     | 0.01455 (Darcy f) |

## Bateman Engineering

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 7                                    | From node to node   | 2 - 3             |
| Description       | Rubber hose                          | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Rubber Hose                          | Pipe Class          |                   |
| Nominal Diameter  | 500 mm                               | Inside Diameter     | 440 mm            |
| Outside Diameter  | 500 mm                               | Pipe Length         | 40 m              |
| Pipe Roughness    | 0.5 mm                               | Allowable Press.    | 100 kPa           |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1.6                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 566.99 m3/hr                         | Velocity            | 1.04 m/s          |
| Friction Loss     | 0.1 m                                | Fitting Losses      | 0.09 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.19 m                               | Total Pressure Drop | 1.88 kPa          |
| Entry Total Head  | 80.95 m                              | Exit Total Head     | 80.76 m           |
| Entry Gauge Head  | 10.95 m                              | Exit Gauge Head     | 6.76 m            |
| Reynolds No.      | 451240.89                            | Friction Factor     | 0.02087 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 8                                    | From node to node   | 3 - 4             |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 020           |
| Nominal Diameter  | 500 mm                               | Inside Diameter     | 489 mm            |
| Outside Diameter  | 508 mm                               | Pipe Length         | 75 m              |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1.2                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 566.99 m3/hr                         | Velocity            | 0.84 m/s          |
| Friction Loss     | 0.08 m                               | Fitting Losses      | 0.04 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.12 m                               | Total Pressure Drop | 1.22 kPa          |
| Entry Total Head  | 80.76 m                              | Exit Total Head     | 80.64 m           |
| Entry Gauge Head  | 6.76 m                               | Exit Gauge Head     | 4.64 m            |
| Reynolds No.      | 406024.52                            | Friction Factor     | 0.01473 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 10                                   | From node to node   | 4 - 9             |
| Description       | 6301-RW-280-PN6.3                    | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN6.3             |
| Nominal Diameter  | 280 mm                               | Inside Diameter     | 252 mm            |
| Outside Diameter  | 280 mm                               | Pipe Length         | 600 m             |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 630 kPa           |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1.48                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 566.99 m3/hr                         | Velocity            | 3.16 m/s          |
| Friction Loss     | 15.31 m                              | Fitting Losses      | 0.75 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 16.07 m                              | Total Pressure Drop | 157.56 kPa        |
| Entry Total Head  | 80.64 m                              | Exit Total Head     | 64.57 m           |
| Entry Gauge Head  | 4.64 m                               | Exit Gauge Head     | -11.43 m          |
| Reynolds No.      | 787880.91                            | Friction Factor     | 0.01265 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 12                                   | From node to node   | 9 - 11            |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 020           |
| Nominal Diameter  | 500 mm                               | Inside Diameter     | 489 mm            |
| Outside Diameter  | 508 mm                               | Pipe Length         | 6 m               |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2.4                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 567 m3/hr                            | Velocity            | 0.84 m/s          |
| Friction Loss     | 0.01 m                               | Fitting Losses      | 0.09 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.09 m                               | Total Pressure Drop | 0.91 kPa          |
| Entry Total Head  | 64.57 m                              | Exit Total Head     | 64.48 m           |
| Entry Gauge Head  | -11.43 m                             | Exit Gauge Head     | -12.32 m          |
| Reynolds No.      | 406032.17                            | Friction Factor     | 0.01473 (Darcy f) |



**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 16                                   | From node to node   | 13 - 14           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 020           |
| Nominal Diameter  | 350 mm                               | Inside Diameter     | 339.8 mm          |
| Outside Diameter  | 355.6 mm                             | Pipe Length         | 4 m               |
| Pipe Roughness    | 0.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0.68                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 660.72 m3/hr                         | Velocity            | 2.02 m/s          |
| Friction Loss     | 0.05 m                               | Fitting Losses      | 0.14 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.2 m                                | Total Pressure Drop | 1.92 kPa          |
| Entry Total Head  | 112.13 m                             | Exit Total Head     | 111.94 m          |
| Entry Gauge Head  | 38.63 m                              | Exit Gauge Head     | 38.94 m           |
| Reynolds No.      | 680896.79                            | Friction Factor     | 0.02196 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 20                                   | From node to node   | 14 - 15           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 400 mm                               | Inside Diameter     | 381 mm            |
| Outside Diameter  | 406.4 mm                             | Pipe Length         | 5 m               |
| Pipe Roughness    | 0.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2.56                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 660.72 m3/hr                         | Velocity            | 1.61 m/s          |
| Friction Loss     | 0.04 m                               | Fitting Losses      | 0.34 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.38 m                               | Total Pressure Drop | 3.68 kPa          |
| Entry Total Head  | 111.94 m                             | Exit Total Head     | 111.56 m          |
| Entry Gauge Head  | 38.94 m                              | Exit Gauge Head     | 38.56 m           |
| Reynolds No.      | 607266.64                            | Friction Factor     | 0.02141 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 21                                   | From node to node   | 15 - 19           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 020           |
| Nominal Diameter  | 300 mm                               | Inside Diameter     | 311.2 mm          |
| Outside Diameter  | 323.9 mm                             | Pipe Length         | 1 m               |
| Pipe Roughness    | 0.5 mm                               | Allowable Press.    | 4500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 660.72 m3/hr                         | Velocity            | 2.41 m/s          |
| Friction Loss     | 0.02 m                               | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.02 m                               | Total Pressure Drop | 0.21 kPa          |
| Entry Total Head  | 111.56 m                             | Exit Total Head     | 111.54 m          |
| Entry Gauge Head  | 38.56 m                              | Exit Gauge Head     | 37.54 m           |
| Reynolds No.      | 743473.78                            | Friction Factor     | 0.02241 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 23                                   | From node to node   | 19 - 22           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 500 mm                               | Inside Diameter     | 477.8 mm          |
| Outside Diameter  | 508 mm                               | Pipe Length         | 30 m              |
| Pipe Roughness    | 1.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0.24                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 660.72 m3/hr                         | Velocity            | 1.02 m/s          |
| Friction Loss     | 0.09 m                               | Fitting Losses      | 0.01 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.1 m                                | Total Pressure Drop | 1.01 kPa          |
| Entry Total Head  | 111.54 m                             | Exit Total Head     | 111.44 m          |
| Entry Gauge Head  | 37.54 m                              | Exit Gauge Head     | 36.44 m           |
| Reynolds No.      | 484238.1                             | Friction Factor     | 0.02678 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 25                                   | From node to node   | 22 - 24           |
| Description       | ST600 main                           | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 600 mm                               | Inside Diameter     | 574.6 mm          |
| Outside Diameter  | 609.6 mm                             | Pipe Length         | 4500 m            |
| Pipe Roughness    | 1.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 4                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 660.72 m3/hr                         | Velocity            | 0.71 m/s          |
| Friction Loss     | 5.11 m                               | Fitting Losses      | 0.1 m             |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 5.21 m                               | Total Pressure Drop | 51.13 kPa         |
| Entry Total Head  | 111.44 m                             | Exit Total Head     | 106.22 m          |
| Entry Gauge Head  | 36.44 m                              | Exit Gauge Head     | 5.22 m            |
| Reynolds No.      | 402661                               | Friction Factor     | 0.02555 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 27                                   | From node to node   | 24 - 26           |
| Description       | ST500 main                           | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 500 mm                               | Inside Diameter     | 477.8 mm          |
| Outside Diameter  | 508 mm                               | Pipe Length         | 464.75 m          |
| Pipe Roughness    | 1.5 mm                               | Allowable Press.    | 4500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 661.38 m3/hr                         | Velocity            | 1.02 m/s          |
| Friction Loss     | 1.39 m                               | Fitting Losses      | 0.16 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 1.55 m                               | Total Pressure Drop | 15.22 kPa         |
| Entry Total Head  | 106.22 m                             | Exit Total Head     | 104.67 m          |
| Entry Gauge Head  | 5.22 m                               | Exit Gauge Head     | 0 m               |
| Reynolds No.      | 484720.59                            | Friction Factor     | 0.02678 (Darcy f) |

## Bateman Engineering

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 32                                   | From node to node   | 28 - 30           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 202.7 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 4.6 m             |
| Pipe Roughness    | 0.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3.48                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 254.97 m3/hr                         | Velocity            | 2.19 m/s          |
| Friction Loss     | 0.14 m                               | Fitting Losses      | 0.85 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.99 m                               | Total Pressure Drop | 9.76 kPa          |
| Entry Total Head  | 199.72 m                             | Exit Total Head     | 198.72 m          |
| Entry Gauge Head  | 104.72 m                             | Exit Gauge Head     | 104.72 m          |
| Reynolds No.      | 440467.96                            | Friction Factor     | 0.02514 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 33                                   | From node to node   | 29 - 30           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 202.7 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 4.6 m             |
| Pipe Roughness    | 0.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3.48                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 256.88 m3/hr                         | Velocity            | 2.21 m/s          |
| Friction Loss     | 0.14 m                               | Fitting Losses      | 0.87 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 1.01 m                               | Total Pressure Drop | 9.9 kPa           |
| Entry Total Head  | 199.73 m                             | Exit Total Head     | 198.72 m          |
| Entry Gauge Head  | 104.73 m                             | Exit Gauge Head     | 104.72 m          |
| Reynolds No.      | 443771.94                            | Friction Factor     | 0.02514 (Darcy f) |



**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 34                                   | From node to node   | 30 - 31           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 250 mm                               | Inside Diameter     | 254.5 mm          |
| Outside Diameter  | 273 mm                               | Pipe Length         | 20 m              |
| Pipe Roughness    | 1.5 mm                               | Allowable Press.    | 1 kPa             |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 5.02                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 511.84 m3/hr                         | Velocity            | 2.79 m/s          |
| Friction Loss     | 1 m                                  | Fitting Losses      | 2 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 3 m                                  | Total Pressure Drop | 29.45 kPa         |
| Entry Total Head  | 198.72 m                             | Exit Total Head     | 195.72 m          |
| Entry Gauge Head  | 104.72 m                             | Exit Gauge Head     | 98.31 m           |
| Reynolds No.      | 704265.67                            | Friction Factor     | 0.03206 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                         |
|-------------------|--------------------------------------|---------------------|-------------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd              |
| Project No.       |                                      | Design Date         | 23/01/2016              |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa              |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                         |
| Pipe No           | 37                                   | From node to node   | 31 - 36                 |
| Description       |                                      | Equipment No        |                         |
| Liquid            | WATER                                | Viscosity           | 1.01 cp                 |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3              |
| Vapour Pressure   | 1.6 kPa                              |                     |                         |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040                 |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 154.1 mm                |
| Outside Diameter  | 168.3 mm                             | Pipe Length         | 20 m                    |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1 kPa                   |
| Orifice Plate Dia | -                                    | Non Return Valve    | Yes                     |
| Total Fittings k  | 4                                    | Total Fittings kf   | 0                       |
| Flow Rate         | 0 m3/hr                              | Velocity            | 0 m/s                   |
| Friction Loss     | 2.28 m                               | Fitting Losses      | 0 m                     |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m                     |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m                     |
| Total Head Loss   | 2.28 m                               | Total Pressure Drop | 22.34 kPa               |
| Entry Total Head  | 198 m                                | Exit Total Head     | 195.72 m                |
| Entry Gauge Head  | 98.31 m                              | Exit Gauge Head     | -4.56 m                 |
| Reynolds No.      | 0                                    | Friction Factor     | 1870120.27839 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 38                                   | From node to node   | 31 - 35           |
| Description       | 6501-250-PV12                        | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 250 mm                               | Inside Diameter     | 253 mm            |
| Outside Diameter  | 280.4 mm                             | Pipe Length         | 1770 m            |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2.4                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 256.87 m3/hr                         | Velocity            | 1.42 m/s          |
| Friction Loss     | 11.68 m                              | Fitting Losses      | 0.25 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 11.92 m                              | Total Pressure Drop | 116.93 kPa        |
| Entry Total Head  | 195.72 m                             | Exit Total Head     | 183.8 m           |
| Entry Gauge Head  | 98.31 m                              | Exit Gauge Head     | 86.8 m            |
| Reynolds No.      | 355526.81                            | Friction Factor     | 0.01625 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 42                                   | From node to node   | 35 - 39           |
| Description       | Line 2 SX-EW                         | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.1 mm          |
| Outside Diameter  | 225.3 mm                             | Pipe Length         | 880 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | 75                                   | Non Return Valve    | No                |
| Total Fittings k  | 1.2                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 323.84 m3/hr                         | Velocity            | 2.78 m/s          |
| Friction Loss     | 27.47 m                              | Fitting Losses      | 0.47 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 57.68 m           |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 85.63 m                              | Total Pressure Drop | 839.72 kPa        |
| Entry Total Head  | 183.8 m                              | Exit Total Head     | 98.17 m           |
| Entry Gauge Head  | 86.8 m                               | Exit Gauge Head     | 0 m               |
| Reynolds No.      | 558358.18                            | Friction Factor     | 0.01612 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 43                                   | From node to node   | 35 - 41           |
| Description       | Mine Town                            | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 475 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 123 m3/hr                            | Velocity            | 2.14 m/s          |
| Friction Loss     | 13.74 m                              | Fitting Losses      | 0.7 m             |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 14.44 m                              | Total Pressure Drop | 141.61 kPa        |
| Entry Total Head  | 183.8 m                              | Exit Total Head     | 169.36 m          |
| Entry Gauge Head  | 86.8 m                               | Exit Gauge Head     | 64.36 m           |
| Reynolds No.      | 301833.46                            | Friction Factor     | 0.01774 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 50                                   | From node to node   | 35 - 45           |
| Description       | Line 1                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.1 mm          |
| Outside Diameter  | 225.3 mm                             | Pipe Length         | 2350 m            |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3.54                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 65 m3/hr                             | Velocity            | 0.56 m/s          |
| Friction Loss     | 3.5 m                                | Fitting Losses      | 0.06 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 3.56 m                               | Total Pressure Drop | 34.91 kPa         |
| Entry Total Head  | 183.8 m                              | Exit Total Head     | 180.24 m          |
| Entry Gauge Head  | 86.8 m                               | Exit Gauge Head     | 77.68 m           |
| Reynolds No.      | 112070.08                            | Friction Factor     | 0.01911 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 51                                   | From node to node   | 45 - 44           |
| Description       | Line 3                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 220 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0.4                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 38 m3/hr                             | Velocity            | 0.66 m/s          |
| Friction Loss     | 0.69 m                               | Fitting Losses      | 0.01 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.7 m                                | Total Pressure Drop | 6.87 kPa          |
| Entry Total Head  | 180.24 m                             | Exit Total Head     | 179.54 m          |
| Entry Gauge Head  | 77.68 m                              | Exit Gauge Head     | 79.54 m           |
| Reynolds No.      | 93249.36                             | Friction Factor     | 0.02019 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 52                                   | From node to node   | 44 - 40           |
| Description       | Line 3                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 125 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2.12                                 | Total Fittings kf   | 0                 |
| Flow Rate         | 36 m3/hr                             | Velocity            | 0.63 m/s          |
| Friction Loss     | 0.36 m                               | Fitting Losses      | 0.04 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.4 m                                | Total Pressure Drop | 3.9 kPa           |
| Entry Total Head  | 179.54 m                             | Exit Total Head     | 179.14 m          |
| Entry Gauge Head  | 79.54 m                              | Exit Gauge Head     | 79.14 m           |
| Reynolds No.      | 88341.5                              | Friction Factor     | 0.02035 (Darcy f) |



**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 53                                   | From node to node   | 45 - 46           |
| Description       | Line 3                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 220 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0.4                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 27 m3/hr                             | Velocity            | 0.47 m/s          |
| Friction Loss     | 0.37 m                               | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.37 m                               | Total Pressure Drop | 3.65 kPa          |
| Entry Total Head  | 180.24 m                             | Exit Total Head     | 179.87 m          |
| Entry Gauge Head  | 77.68 m                              | Exit Gauge Head     | 81.87 m           |
| Reynolds No.      | 66256.13                             | Friction Factor     | 0.02128 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 54                                   | From node to node   | 47 - 49           |
| Description       | Line 4                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 535 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 2 m3/hr                              | Velocity            | 0.03 m/s          |
| Friction Loss     | 0.01 m                               | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.01 m                               | Total Pressure Drop | 0.09 kPa          |
| Entry Total Head  | 179.17 m                             | Exit Total Head     | 179.16 m          |
| Entry Gauge Head  | 63.17 m                              | Exit Gauge Head     | 44.16 m           |
| Reynolds No.      | 4907.86                              | Friction Factor     | 0.03806 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 55                                   | From node to node   | 47 - 48           |
| Description       | Line 3                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 250 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 10 m3/hr                             | Velocity            | 0.17 m/s          |
| Friction Loss     | 0.07 m                               | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.07 m                               | Total Pressure Drop | 0.68 kPa          |
| Entry Total Head  | 179.17 m                             | Exit Total Head     | 179.1 m           |
| Entry Gauge Head  | 63.17 m                              | Exit Gauge Head     | 66.1 m            |
| Reynolds No.      | 24539.31                             | Friction Factor     | 0.02563 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 57                                   | From node to node   | 46 - 56           |
| Description       | Line 3                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 250 m             |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 22 m3/hr                             | Velocity            | 0.38 m/s          |
| Friction Loss     | 0.29 m                               | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.29 m                               | Total Pressure Drop | 2.82 kPa          |
| Entry Total Head  | 179.87 m                             | Exit Total Head     | 179.58 m          |
| Entry Gauge Head  | 81.87 m                              | Exit Gauge Head     | 63.58 m           |
| Reynolds No.      | 53986.47                             | Friction Factor     | 0.02202 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 58                                   | From node to node   | 56 - 47           |
| Description       | Line 3                               | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 150 mm                               | Inside Diameter     | 142.7 mm          |
| Outside Diameter  | 160.3 mm                             | Pipe Length         | 1070 m            |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 0                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 12 m3/hr                             | Velocity            | 0.21 m/s          |
| Friction Loss     | 0.41 m                               | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.41 m                               | Total Pressure Drop | 4.02 kPa          |
| Entry Total Head  | 179.58 m                             | Exit Total Head     | 179.17 m          |
| Entry Gauge Head  | 63.58 m                              | Exit Gauge Head     | 63.17 m           |
| Reynolds No.      | 29447.17                             | Friction Factor     | 0.02468 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 63                                   | From node to node   | 59 - 62           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN16              |
| Nominal Diameter  | 160 mm                               | Inside Diameter     | 123 mm            |
| Outside Diameter  | 160 mm                               | Pipe Length         | 3 m               |
| Pipe Roughness    | 0.003 mm                             | Allowable Press.    | 1600 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3.5                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 77.39 m3/hr                          | Velocity            | 1.81 m/s          |
| Friction Loss     | 0.06 m                               | Fitting Losses      | 0.58 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.65 m                               | Total Pressure Drop | 6.35 kPa          |
| Entry Total Head  | 74.77 m                              | Exit Total Head     | 74.12 m           |
| Entry Gauge Head  | 79.77 m                              | Exit Gauge Head     | 79.12 m           |
| Reynolds No.      | 220327.83                            | Friction Factor     | 0.01555 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 64                                   | From node to node   | 62 - 61           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN16              |
| Nominal Diameter  | 160 mm                               | Inside Diameter     | 123 mm            |
| Outside Diameter  | 160 mm                               | Pipe Length         | 172.5 m           |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 1600 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2.5                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 77.39 m3/hr                          | Velocity            | 1.81 m/s          |
| Friction Loss     | 3.7 m                                | Fitting Losses      | 0.42 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 4.12 m                               | Total Pressure Drop | 40.41 kPa         |
| Entry Total Head  | 74.12 m                              | Exit Total Head     | 70 m              |
| Entry Gauge Head  | 79.12 m                              | Exit Gauge Head     | 0 m               |
| Reynolds No.      | 220327.83                            | Friction Factor     | 0.01582 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                 |
|-------------------|--------------------------------------|---------------------|-----------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd      |
| Project No.       |                                      | Design Date         | 23/01/2016      |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa      |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                 |
| Pipe No           | 68                                   | From node to node   | 60 - 67         |
| Description       |                                      | Equipment No        |                 |
| Liquid            | WATER                                | Viscosity           | 1.01 cp         |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3      |
| Vapour Pressure   | 1.6 kPa                              |                     |                 |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN6.3           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 180 mm          |
| Outside Diameter  | 200 mm                               | Pipe Length         | 100 m           |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 630 kPa         |
| Orifice Plate Dia | -                                    | Non Return Valve    | No              |
| Total Fittings k  | 3.5                                  | Total Fittings kf   | 0               |
| Flow Rate         | 222.42 m3/hr                         | Velocity            | 2.43 m/s        |
| Friction Loss     | 2.34 m                               | Fitting Losses      | 1.05 m          |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m             |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m             |
| Total Head Loss   | 3.39 m                               | Total Pressure Drop | 33.25 kPa       |
| Entry Total Head  | 108.17 m                             | Exit Total Head     | 104.78 m        |
| Entry Gauge Head  | 38.17 m                              | Exit Gauge Head     | 23.28 m         |
| Reynolds No.      | 432704.73                            | Friction Factor     | 0.014 (Darcy f) |



**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 70                                   | From node to node   | 67 - 69           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN6.3             |
| Nominal Diameter  | 315 mm                               | Inside Diameter     | 283 mm            |
| Outside Diameter  | 315 mm                               | Pipe Length         | 615 m             |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 500 kPa           |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 222.42 m3/hr                         | Velocity            | 0.98 m/s          |
| Friction Loss     | 1.6 m                                | Fitting Losses      | 0.15 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 1.75 m                               | Total Pressure Drop | 17.12 kPa         |
| Entry Total Head  | 104.78 m                             | Exit Total Head     | 103.03 m          |
| Entry Gauge Head  | 23.28 m                              | Exit Gauge Head     | 1.03 m            |
| Reynolds No.      | 275218.55                            | Friction Factor     | 0.01494 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                 |
|-------------------|--------------------------------------|---------------------|-----------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd      |
| Project No.       |                                      | Design Date         | 23/01/2016      |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa      |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                 |
| Pipe No           | 71                                   | From node to node   | 69 - 39         |
| Description       | Pit Water Line                       | Equipment No        |                 |
| Liquid            | WATER                                | Viscosity           | 1.01 cp         |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3      |
| Vapour Pressure   | 1.6 kPa                              |                     |                 |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN12.5          |
| Nominal Diameter  | 355 mm                               | Inside Diameter     | 289 mm          |
| Outside Diameter  | 355 mm                               | Pipe Length         | 2023 m          |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 100 kPa         |
| Orifice Plate Dia | -                                    | Non Return Valve    | No              |
| Total Fittings k  | 2.5                                  | Total Fittings kf   | 0               |
| Flow Rate         | 222.42 m3/hr                         | Velocity            | 0.94 m/s        |
| Friction Loss     | 4.75 m                               | Fitting Losses      | 0.11 m          |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m             |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m             |
| Total Head Loss   | 4.86 m                               | Total Pressure Drop | 47.68 kPa       |
| Entry Total Head  | 103.03 m                             | Exit Total Head     | 98.17 m         |
| Entry Gauge Head  | 1.03 m                               | Exit Gauge Head     | 0 m             |
| Reynolds No.      | 269504.67                            | Friction Factor     | 0.015 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                        |
|-------------------|--------------------------------------|---------------------|------------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd             |
| Project No.       |                                      | Design Date         | 23/01/2016             |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa             |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                        |
| Pipe No           | 72                                   | From node to node   | 66 - 69                |
| Description       |                                      | Equipment No        |                        |
| Liquid            | WATER                                | Viscosity           | 1.01 cp                |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3             |
| Vapour Pressure   | 1.6 kPa                              |                     |                        |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN6.3                  |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 180 mm                 |
| Outside Diameter  | 200 mm                               | Pipe Length         | 55 m                   |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 630 kPa                |
| Orifice Plate Dia | -                                    | Non Return Valve    | Yes                    |
| Total Fittings k  | 0                                    | Total Fittings kf   | 0                      |
| Flow Rate         | 0 m3/hr                              | Velocity            | 0 m/s                  |
| Friction Loss     | 13.03 m                              | Fitting Losses      | 0 m                    |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m                    |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m                    |
| Total Head Loss   | 13.03 m                              | Total Pressure Drop | 127.8 kPa              |
| Entry Total Head  | 103.03 m                             | Exit Total Head     | 90 m                   |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -25.03 m               |
| Reynolds No.      | 0                                    | Friction Factor     | 899123.09654 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                  |
|-------------------|--------------------------------------|---------------------|------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd       |
| Project No.       |                                      | Design Date         | 23/01/2016       |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa       |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                  |
| Pipe No           | 73                                   | From node to node   | 9 - 17           |
| Description       |                                      | Equipment No        |                  |
| Liquid            | WATER                                | Viscosity           | 1.01 cp          |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3       |
| Vapour Pressure   | 1.6 kPa                              |                     |                  |
| Pipe Description  | Steel ANSI BS36.10                   | Pipe Class          | Sch 020          |
| Nominal Diameter  | 500 mm                               | Inside Diameter     | 2 mm             |
| Outside Diameter  | 508 mm                               | Pipe Length         | 6 m              |
| Pipe Roughness    | 1.5 mm                               | Allowable Press.    | 1500 kPa         |
| Orifice Plate Dia | -                                    | Non Return Valve    | No               |
| Total Fittings k  | 2.4                                  | Total Fittings kf   | 0                |
| Flow Rate         | 0.02 m3/hr                           | Velocity            | 1.68 m/s         |
| Friction Loss     | 11.88 m                              | Fitting Losses      | 0.35 m           |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m              |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m              |
| Total Head Loss   | 12.23 m                              | Total Pressure Drop | 119.91 kPa       |
| Entry Total Head  | 76.8 m                               | Exit Total Head     | 64.57 m          |
| Entry Gauge Head  | -11.43 m                             | Exit Gauge Head     | -24.46 m         |
| Reynolds No.      | 3335.7                               | Friction Factor     | 0.5237 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 75                                   | From node to node   | 74 - 39           |
| Description       | 160 PE 6.3                           | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN6.3             |
| Nominal Diameter  | 160 mm                               | Inside Diameter     | 144 mm            |
| Outside Diameter  | 160 mm                               | Pipe Length         | 600 m             |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 630 kPa           |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 148.03 m3/hr                         | Velocity            | 2.52 m/s          |
| Friction Loss     | 19.67 m                              | Fitting Losses      | 0.98 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 20.65 m                              | Total Pressure Drop | 202.49 kPa        |
| Entry Total Head  | 118.82 m                             | Exit Total Head     | 98.17 m           |
| Entry Gauge Head  | 26.82 m                              | Exit Gauge Head     | 0 m               |
| Reynolds No.      | 359975.11                            | Friction Factor     | 0.01452 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 77                                   | From node to node   | 31 - 76           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 250 mm                               | Inside Diameter     | 253 mm            |
| Outside Diameter  | 280.4 mm                             | Pipe Length         | 10 m              |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 254.98 m3/hr                         | Velocity            | 1.41 m/s          |
| Friction Loss     | 0.07 m                               | Fitting Losses      | 0.1 m             |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.17 m                               | Total Pressure Drop | 1.63 kPa          |
| Entry Total Head  | 195.72 m                             | Exit Total Head     | 195.56 m          |
| Entry Gauge Head  | 98.31 m                              | Exit Gauge Head     | 95.56 m           |
| Reynolds No.      | 352914.35                            | Friction Factor     | 0.01626 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 78                                   | From node to node   | 76 - 35           |
| Description       | New 250 NB PV12 pipe                 | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | uPVC RRJ Pipe AS1477                 | Pipe Class          | 12                |
| Nominal Diameter  | 250 mm                               | Inside Diameter     | 253 mm            |
| Outside Diameter  | 280.4 mm                             | Pipe Length         | 1770 m            |
| Pipe Roughness    | 0.06 mm                              | Allowable Press.    | 1200 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2.4                                  | Total Fittings kf   | 0                 |
| Flow Rate         | 254.98 m3/hr                         | Velocity            | 1.41 m/s          |
| Friction Loss     | 11.51 m                              | Fitting Losses      | 0.24 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 11.76 m                              | Total Pressure Drop | 115.3 kPa         |
| Entry Total Head  | 195.56 m                             | Exit Total Head     | 183.8 m           |
| Entry Gauge Head  | 95.56 m                              | Exit Gauge Head     | 86.8 m            |
| Reynolds No.      | 352914.35                            | Friction Factor     | 0.01626 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 79                                   | From node to node   | 18 - 0            |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.3 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 8 m               |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 2                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 566.99 m3/hr                         | Velocity            | 4.85 m/s          |
| Friction Loss     | 0.71 m                               | Fitting Losses      | 2.4 m             |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 3.11 m                               | Total Pressure Drop | 30.46 kPa         |
| Entry Total Head  | 64.68 m                              | Exit Total Head     | 61.57 m           |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -12.43 m          |
| Reynolds No.      | 976615.79                            | Friction Factor     | 0.01493 (Darcy f) |



**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 81                                   | From node to node   | 80 - 13           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.3 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 2 m               |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 660.73 m3/hr                         | Velocity            | 5.65 m/s          |
| Friction Loss     | 0.24 m                               | Fitting Losses      | 1.63 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 1.87 m                               | Total Pressure Drop | 18.32 kPa         |
| Entry Total Head  | 73.5 m                               | Exit Total Head     | 71.63 m           |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -1.87 m           |
| Reynolds No.      | 1138084.41                           | Friction Factor     | 0.01481 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 82                                   | From node to node   | 65 - 66           |
| Description       | Open Pit Dewatering                  | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.3 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 3 m               |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 3                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 1.24 m3/hr                           | Velocity            | 0.01 m/s          |
| Friction Loss     | 0 m                                  | Fitting Losses      | 0 m               |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0 m                                  | Total Pressure Drop | 0 kPa             |
| Entry Total Head  | 90 m                                 | Exit Total Head     | 90 m              |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | 0 m               |
| Reynolds No.      | 2143.14                              | Friction Factor     | 0.04854 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 84                                   | From node to node   | 83 - 59           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN16              |
| Nominal Diameter  | 160 mm                               | Inside Diameter     | 123 mm            |
| Outside Diameter  | 160 mm                               | Pipe Length         | 3 m               |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 1600 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 77.39 m3/hr                          | Velocity            | 1.81 m/s          |
| Friction Loss     | 0.06 m                               | Fitting Losses      | 0.17 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.23 m                               | Total Pressure Drop | 2.27 kPa          |
| Entry Total Head  | -5 m                                 | Exit Total Head     | -5.23 m           |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -0.23 m           |
| Reynolds No.      | 220327.83                            | Friction Factor     | 0.01582 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 86                                   | From node to node   | 85 - 29           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040           |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.3 mm          |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 1 m               |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1500 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 256.88 m3/hr                         | Velocity            | 2.2 m/s           |
| Friction Loss     | 0.02 m                               | Fitting Losses      | 0.25 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.27 m                               | Total Pressure Drop | 2.6 kPa           |
| Entry Total Head  | 95 m                                 | Exit Total Head     | 94.73 m           |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -0.27 m           |
| Reynolds No.      | 442462.38                            | Friction Factor     | 0.01579 (Darcy f) |

## Bateman Engineering

|                   |                                      |                     |                  |
|-------------------|--------------------------------------|---------------------|------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd       |
| Project No.       |                                      | Design Date         | 23/01/2016       |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa       |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                  |
| Pipe No           | 88                                   | From node to node   | 87 - 28          |
| Description       |                                      | Equipment No        |                  |
| Liquid            | WATER                                | Viscosity           | 1.01 cp          |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3       |
| Vapour Pressure   | 1.6 kPa                              |                     |                  |
| Pipe Description  | Steel B36.10                         | Pipe Class          | Sch 040          |
| Nominal Diameter  | 200 mm                               | Inside Diameter     | 203.3 mm         |
| Outside Diameter  | 219.1 mm                             | Pipe Length         | 2 m              |
| Pipe Roughness    | 0.045 mm                             | Allowable Press.    | 1500 kPa         |
| Orifice Plate Dia | -                                    | Non Return Valve    | No               |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                |
| Flow Rate         | 254.98 m3/hr                         | Velocity            | 2.18 m/s         |
| Friction Loss     | 0.04 m                               | Fitting Losses      | 0.24 m           |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m              |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m              |
| Total Head Loss   | 0.28 m                               | Total Pressure Drop | 2.75 kPa         |
| Entry Total Head  | 95 m                                 | Exit Total Head     | 94.72 m          |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -0.28 m          |
| Reynolds No.      | 439184.29                            | Friction Factor     | 0.0158 (Darcy f) |

## Bateman Engineering

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 90                                   | From node to node   | 89 - 74           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN16              |
| Nominal Diameter  | 160 mm                               | Inside Diameter     | 123 mm            |
| Outside Diameter  | 160 mm                               | Pipe Length         | 1 m               |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 1600 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 148.03 m3/hr                         | Velocity            | 3.46 m/s          |
| Friction Loss     | 0.07 m                               | Fitting Losses      | 0.61 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 0.68 m                               | Total Pressure Drop | 6.68 kPa          |
| Entry Total Head  | 92 m                                 | Exit Total Head     | 91.32 m           |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -0.68 m           |
| Reynolds No.      | 421434.27                            | Friction Factor     | 0.01427 (Darcy f) |

**Bateman Engineering**

|                   |                                      |                     |                   |
|-------------------|--------------------------------------|---------------------|-------------------|
| Project           | Water Supply Review                  | Client              | MMICCL Ltd        |
| Project No.       |                                      | Design Date         | 23/01/2016        |
| Category          | Demo Liquid Mine Water System        | Atmos. Press        | 100.21 kPa        |
| Description       | MICCL Water Supply PS1-PS3 Upgrade 2 |                     |                   |
| Pipe No           | 92                                   | From node to node   | 91 - 60           |
| Description       |                                      | Equipment No        |                   |
| Liquid            | WATER                                | Viscosity           | 1.01 cp           |
| Temperature       | 20 C                                 | Density             | 1000 kg/m3        |
| Vapour Pressure   | 1.6 kPa                              |                     |                   |
| Pipe Description  | Polyethylene PE80 AS4130             | Pipe Class          | PN16              |
| Nominal Diameter  | 160 mm                               | Inside Diameter     | 123 mm            |
| Outside Diameter  | 160 mm                               | Pipe Length         | 3 m               |
| Pipe Roughness    | 0.007 mm                             | Allowable Press.    | 1600 kPa          |
| Orifice Plate Dia | -                                    | Non Return Valve    | No                |
| Total Fittings k  | 1                                    | Total Fittings kf   | 0                 |
| Flow Rate         | 222.42 m3/hr                         | Velocity            | 5.2 m/s           |
| Friction Loss     | 0.45 m                               | Fitting Losses      | 1.38 m            |
| Slurry Losses     | 0 m                                  | Orifice Losses      | 0 m               |
| Fixed Head Loss   | 0 m                                  | Booster Pump Head   | 0 m               |
| Total Head Loss   | 1.83 m                               | Total Pressure Drop | 17.97 kPa         |
| Entry Total Head  | 70 m                                 | Exit Total Head     | 68.17 m           |
| Entry Gauge Head  | 0 m                                  | Exit Gauge Head     | -1.83 m           |
| Reynolds No.      | 633226.43                            | Friction Factor     | 0.01349 (Darcy f) |

**Bateman Engineering**

|                       |                                      |                      |                  |
|-----------------------|--------------------------------------|----------------------|------------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd       |
| Project No.           |                                      | Design Date          | 23/01/2016       |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa       |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |                  |
| Node No               | 0                                    | Node Type            | Pump             |
| Description           | PS1                                  | Equipment No         | Galligher 8 inch |
| Rel. Level (RL)       | 74 m                                 | Pressure Input       | 0 kPa            |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -                |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -                |
| Total Node Head       | 86.07 m                              |                      |                  |
| Pump Head             | 24.5 m                               | Pump Flow Rate       | 566.99 m3/hr     |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 54.06 kW         |
| Casing Pressure       | 118.4 kPa                            |                      |                  |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | -2.37 m          |



**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |         |                      |           |
|------------------|---------|----------------------|-----------|
| Node No          | 1       | Node Type            | Junction  |
| Description      |         | Equipment No         |           |
| Rel. Level (RL)  | 65 m    | Pressure Input       | 0 kPa     |
| Nozzle K value   | -       | Ext Flow (+In/-Out)  | 0 m3/hr   |
| Int.(Gauge) Head | 16.17 m | Int.(Gauge) Pressure | 158.6 kPa |
| Total Node Head  | 81.17 m |                      |           |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 2                                    | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 70 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 10.95 m                              | Int.(Gauge) Pressure | 107.42 kPa |
| Total Node Head  | 80.95 m                              |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |         |                      |           |
|------------------|---------|----------------------|-----------|
| Node No          | 3       | Node Type            | Junction  |
| Description      |         | Equipment No         |           |
| Rel. Level (RL)  | 74 m    | Pressure Input       | 0 kPa     |
| Nozzle K value   | -       | Ext Flow (+In/-Out)  | 0 m3/hr   |
| Int.(Gauge) Head | 6.76 m  | Int.(Gauge) Pressure | 66.32 kPa |
| Total Node Head  | 80.76 m |                      |           |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |         |                      |           |
|------------------|---------|----------------------|-----------|
| Node No          | 4       | Node Type            | Junction  |
| Description      |         | Equipment No         |           |
| Rel. Level (RL)  | 76 m    | Pressure Input       | 0 kPa     |
| Nozzle K value   | -       | Ext Flow (+In/-Out)  | 0 m3/hr   |
| Int.(Gauge) Head | 4.64 m  | Int.(Gauge) Pressure | 45.49 kPa |
| Total Node Head  | 80.64 m |                      |           |

**Bateman Engineering**

|                  |                                      |                      |             |
|------------------|--------------------------------------|----------------------|-------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd  |
| Project No.      |                                      | Design Date          | 23/01/2016  |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa  |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |             |
| Node No          | 9                                    | Node Type            | Junction    |
| Description      |                                      | Equipment No         |             |
| Rel. Level (RL)  | 76 m                                 | Pressure Input       | 0 kPa       |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr     |
| Int.(Gauge) Head | -11.43 m                             | Int.(Gauge) Pressure | -112.07 kPa |
| Total Node Head  | 64.57 m                              |                      |             |

**Bateman Engineering**

|                  |                                      |                      |             |
|------------------|--------------------------------------|----------------------|-------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd  |
| Project No.      |                                      | Design Date          | 23/01/2016  |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa  |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |             |
| Node No          | 11                                   | Node Type            | Junction    |
| Description      | PS2 Settling Tank                    | Equipment No         |             |
| Rel. Level (RL)  | 76.8 m                               | Pressure Input       | 0 kPa       |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -567 m3/hr  |
| Int.(Gauge) Head | -12.32 m                             | Int.(Gauge) Pressure | -120.82 kPa |
| Total Node Head  | 64.48 m                              |                      |             |

**Bateman Engineering**

|                       |                                      |                      |              |
|-----------------------|--------------------------------------|----------------------|--------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd   |
| Project No.           |                                      | Design Date          | 23/01/2016   |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa   |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |              |
| Node No               | 13                                   | Node Type            | Pump         |
| Description           | PS2 Pump 1 63-PP-03                  | Equipment No         | 63-PP-03     |
| Rel. Level (RL)       | 73.5 m                               | Pressure Input       | 0 kPa        |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -            |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -            |
| Total Node Head       | 112.13 m                             |                      |              |
| Pump Head             | 40.5 m                               | Pump Flow Rate       | 660.68 m3/hr |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 104.13 kW    |
| Casing Pressure       | 378.85 kPa                           |                      |              |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 8.19 m       |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 14                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 73 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 38.94 m                              | Int.(Gauge) Pressure | 381.83 kPa |
| Total Node Head  | 111.94 m                             |                      |            |



**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 15                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 73 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 38.56 m                              | Int.(Gauge) Pressure | 378.15 kPa |
| Total Node Head  | 111.56 m                             |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                    |                      |       |
|------------------|--------------------|----------------------|-------|
| Node No          | 17                 | Node Type            | Tank  |
| Description      | PS 2 Settling Tank | Equipment No         |       |
| Rel. Level (RL)  | 76.8 m             | Pressure Input       | 0 kPa |
| Nozzle K value   | -                  | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -                  | Int.(Gauge) Pressure | -     |
| Total Node Head  | 76.8 m             |                      |       |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                |                      |                   |
|------------------|----------------|----------------------|-------------------|
| Node No          | 18             | Node Type            | Tank              |
| Description      | Chindwin River | Equipment No         | RL 64.68 to 74.18 |
| Rel. Level (RL)  | 64.68 m        | Pressure Input       | 0 kPa             |
| Nozzle K value   | -              | Ext Flow (+In/-Out)  | -                 |
| Int.(Gauge) Head | -              | Int.(Gauge) Pressure | -                 |
| Total Node Head  | 64.68 m        |                      |                   |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 19                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 74 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 37.54 m                              | Int.(Gauge) Pressure | 368.13 kPa |
| Total Node Head  | 111.54 m                             |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |          |                      |            |
|------------------|----------|----------------------|------------|
| Node No          | 22       | Node Type            | Junction   |
| Description      |          | Equipment No         |            |
| Rel. Level (RL)  | 75 m     | Pressure Input       | 0 kPa      |
| Nozzle K value   | -        | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 36.44 m  | Int.(Gauge) Pressure | 357.32 kPa |
| Total Node Head  | 111.44 m |                      |            |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 24                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 101 m                                | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 5.22 m                               | Int.(Gauge) Pressure | 51.21 kPa  |
| Total Node Head  | 106.22 m                             |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                        |                      |          |
|------------------|------------------------|----------------------|----------|
| Node No          | 26                     | Node Type            | Tank     |
| Description      | PS3 Reservoir 63-TK-05 | Equipment No         | 63-TK-05 |
| Rel. Level (RL)  | 104.67 m               | Pressure Input       | 0 kPa    |
| Nozzle K value   | -                      | Ext Flow (+In/-Out)  | -        |
| Int.(Gauge) Head | -                      | Int.(Gauge) Pressure | -        |
| Total Node Head  | 104.67 m               |                      |          |

**Bateman Engineering**

|                       |                                      |                      |              |
|-----------------------|--------------------------------------|----------------------|--------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd   |
| Project No.           |                                      | Design Date          | 23/01/2016   |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa   |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |              |
| Node No               | 28                                   | Node Type            | Pump         |
| Description           | 63-PP-03                             | Equipment No         |              |
| Rel. Level (RL)       | 95 m                                 | Pressure Input       | 0 kPa        |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -            |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -            |
| Total Node Head       | 199.72 m                             |                      |              |
| Pump Head             | 105 m                                | Pump Flow Rate       | 254.98 m3/hr |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 104.19 kW    |
| Casing Pressure       | 1026.95 kPa                          |                      |              |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 9.77 m       |



**Bateman Engineering**

|                       |                                      |                      |              |
|-----------------------|--------------------------------------|----------------------|--------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd   |
| Project No.           |                                      | Design Date          | 23/01/2016   |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa   |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |              |
| Node No               | 29                                   | Node Type            | Pump         |
| Description           | Spare Pump                           | Equipment No         |              |
| Rel. Level (RL)       | 95 m                                 | Pressure Input       | 0 kPa        |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -            |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -            |
| Total Node Head       | 199.73 m                             |                      |              |
| Pump Head             | 105 m                                | Pump Flow Rate       | 256.88 m3/hr |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 104.96 kW    |
| Casing Pressure       | 1027.09 kPa                          |                      |              |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 9.79 m       |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |          |                      |          |
|------------------|----------|----------------------|----------|
| Node No          | 30       | Node Type            | Junction |
| Description      |          | Equipment No         |          |
| Rel. Level (RL)  | 94 m     | Pressure Input       | 0 kPa    |
| Nozzle K value   | -        | Ext Flow (+In/-Out)  | 0 m3/hr  |
| Int.(Gauge) Head | 104.72 m | Int.(Gauge) Pressure | 1027 kPa |
| Total Node Head  | 198.72 m |                      |          |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                |                      |            |
|------------------|----------------|----------------------|------------|
| Node No          | 31             | Node Type            | Junction   |
| Description      | Junct 250 PV12 | Equipment No         |            |
| Rel. Level (RL)  | 97.414 m       | Pressure Input       | 0 kPa      |
| Nozzle K value   | -              | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 98.31 m        | Int.(Gauge) Pressure | 964.07 kPa |
| Total Node Head  | 195.72 m       |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |         |                      |           |
|------------------|---------|----------------------|-----------|
| Node No          | 35      | Node Type            | Junction  |
| Description      |         | Equipment No         |           |
| Rel. Level (RL)  | 97 m    | Pressure Input       | 0 kPa     |
| Nozzle K value   | -       | Ext Flow (+In/-Out)  | 0 m3/hr   |
| Int.(Gauge) Head | 86.8 m  | Int.(Gauge) Pressure | 851.2 kPa |
| Total Node Head  | 183.8 m |                      |           |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |            |                      |       |
|------------------|------------|----------------------|-------|
| Node No          | 36         | Node Type            | Tank  |
| Description      | PRV bypass | Equipment No         |       |
| Rel. Level (RL)  | 198 m      | Pressure Input       | 0 kPa |
| Nozzle K value   | -          | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -          | Int.(Gauge) Pressure | -     |
| Total Node Head  | 198 m      |                      |       |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                |                      |       |
|------------------|----------------|----------------------|-------|
| Node No          | 39             | Node Type            | Tank  |
| Description      | SX-EW Raf Pond | Equipment No         |       |
| Rel. Level (RL)  | 98.17 m        | Pressure Input       | 0 kPa |
| Nozzle K value   | -              | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -              | Int.(Gauge) Pressure | -     |
| Total Node Head  | 98.17 m        |                      |       |

**Bateman Engineering**

|                  |                                      |                      |                        |
|------------------|--------------------------------------|----------------------|------------------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd             |
| Project No.      |                                      | Design Date          | 23/01/2016             |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa             |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |                        |
| Node No          | 40                                   | Node Type            | Junction               |
| Description      | Crusher                              | Equipment No         |                        |
| Rel. Level (RL)  | 100 m                                | Pressure Input       | 0 kPa                  |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -36 m <sup>3</sup> /hr |
| Int.(Gauge) Head | 79.14 m                              | Int.(Gauge) Pressure | 776.1 kPa              |
| Total Node Head  | 179.14 m                             |                      |                        |

**Bateman Engineering**

|                  |                                      |                      |                         |
|------------------|--------------------------------------|----------------------|-------------------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd              |
| Project No.      |                                      | Design Date          | 23/01/2016              |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa              |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |                         |
| Node No          | 41                                   | Node Type            | Junction                |
| Description      | Mine Town                            | Equipment No         |                         |
| Rel. Level (RL)  | 105 m                                | Pressure Input       | 0 kPa                   |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -123 m <sup>3</sup> /hr |
| Int.(Gauge) Head | 64.36 m                              | Int.(Gauge) Pressure | 631.14 kPa              |
| Total Node Head  | 169.36 m                             |                      |                         |



**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |            |                      |          |
|------------------|------------|----------------------|----------|
| Node No          | 44         | Node Type            | Junction |
| Description      | Fuel Depot | Equipment No         |          |
| Rel. Level (RL)  | 100 m      | Pressure Input       | 0 kPa    |
| Nozzle K value   | -          | Ext Flow (+In/-Out)  | -2 m3/hr |
| Int.(Gauge) Head | 79.54 m    | Int.(Gauge) Pressure | 780 kPa  |
| Total Node Head  | 179.54 m   |                      |          |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 45                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 102.56 m                             | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 77.68 m                              | Int.(Gauge) Pressure | 761.77 kPa |
| Total Node Head  | 180.24 m                             |                      |            |

**Bateman Engineering**

|                  |                                      |                      |                       |
|------------------|--------------------------------------|----------------------|-----------------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd            |
| Project No.      |                                      | Design Date          | 23/01/2016            |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa            |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |                       |
| Node No          | 46                                   | Node Type            | Junction              |
| Description      | Workshops                            | Equipment No         |                       |
| Rel. Level (RL)  | 98 m                                 | Pressure Input       | 0 kPa                 |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -5 m <sup>3</sup> /hr |
| Int.(Gauge) Head | 81.87 m                              | Int.(Gauge) Pressure | 802.83 kPa            |
| Total Node Head  | 179.87 m                             |                      |                       |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |          |                      |            |
|------------------|----------|----------------------|------------|
| Node No          | 47       | Node Type            | Junction   |
| Description      |          | Equipment No         |            |
| Rel. Level (RL)  | 116 m    | Pressure Input       | 0 kPa      |
| Nozzle K value   | -        | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 63.17 m  | Int.(Gauge) Pressure | 619.48 kPa |
| Total Node Head  | 179.17 m |                      |            |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 48                                   | Node Type            | Junction   |
| Description      | 23-CV-03 Drive                       | Equipment No         |            |
| Rel. Level (RL)  | 113 m                                | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -10 m3/hr  |
| Int.(Gauge) Head | 66.1 m                               | Int.(Gauge) Pressure | 648.22 kPa |
| Total Node Head  | 179.1 m                              |                      |            |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 49                                   | Node Type            | Junction   |
| Description      | Anfo Store                           | Equipment No         |            |
| Rel. Level (RL)  | 135 m                                | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -2 m3/hr   |
| Int.(Gauge) Head | 44.16 m                              | Int.(Gauge) Pressure | 433.07 kPa |
| Total Node Head  | 179.16 m                             |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |             |                      |           |
|------------------|-------------|----------------------|-----------|
| Node No          | 56          | Node Type            | Junction  |
| Description      | Aglomerator | Equipment No         |           |
| Rel. Level (RL)  | 116 m       | Pressure Input       | 0 kPa     |
| Nozzle K value   | -           | Ext Flow (+In/-Out)  | -10 m3/hr |
| Int.(Gauge) Head | 63.58 m     | Int.(Gauge) Pressure | 623.5 kPa |
| Total Node Head  | 179.58 m    |                      |           |

**Bateman Engineering**

|                       |                                      |                      |             |
|-----------------------|--------------------------------------|----------------------|-------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd  |
| Project No.           |                                      | Design Date          | 23/01/2016  |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa  |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |             |
| Node No               | 59                                   | Node Type            | Pump        |
| Description           | Pit Dew 61-PP-02                     | Equipment No         | RL495       |
| Rel. Level (RL)       | -5 m                                 | Pressure Input       | 0 kPa       |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -           |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -           |
| Total Node Head       | 74.77 m                              |                      |             |
| Pump Head             | 80 m                                 | Pump Flow Rate       | 77.39 m3/hr |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 24.09 kW    |
| Casing Pressure       | 782.26 kPa                           |                      |             |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 9.82 m      |



**Bateman Engineering**

|                       |                                      |                      |              |
|-----------------------|--------------------------------------|----------------------|--------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd   |
| Project No.           |                                      | Design Date          | 23/01/2016   |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa   |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |              |
| Node No               | 60                                   | Node Type            | Pump         |
| Description           | Pit Transfer pump                    | Equipment No         | 62-PP-02C/D  |
| Rel. Level (RL)       | 70 m                                 | Pressure Input       | 0 kPa        |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -            |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -            |
| Total Node Head       | 108.17 m                             |                      |              |
| Pump Head             | 40 m                                 | Pump Flow Rate       | 222.42 m3/hr |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 34.62 kW     |
| Casing Pressure       | 374.3 kPa                            |                      |              |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 8.22 m       |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                  |                      |       |
|------------------|------------------|----------------------|-------|
| Node No          | 61               | Node Type            | Tank  |
| Description      | Pit Transfer Stn | Equipment No         | RL570 |
| Rel. Level (RL)  | 70 m             | Pressure Input       | 0 kPa |
| Nozzle K value   | -                | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -                | Int.(Gauge) Pressure | -     |
| Total Node Head  | 70 m             |                      |       |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 62                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | -5 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 79.12 m                              | Int.(Gauge) Pressure | 775.91 kPa |
| Total Node Head  | 74.12 m                              |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |               |                      |       |
|------------------|---------------|----------------------|-------|
| Node No          | 65            | Node Type            | Tank  |
| Description      | Overflow Pond | Equipment No         |       |
| Rel. Level (RL)  | 90 m          | Pressure Input       | 0 kPa |
| Nozzle K value   | -             | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -             | Int.(Gauge) Pressure | -     |
| Total Node Head  | 90 m          |                      |       |

**Bateman Engineering**

|                       |                                      |                      |            |
|-----------------------|--------------------------------------|----------------------|------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.           |                                      | Design Date          | 23/01/2016 |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No               | 66                                   | Node Type            | Pump       |
| Description           | Settling Pond Pump                   | Equipment No         |            |
| Rel. Level (RL)       | 90 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -          |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -          |
| Total Node Head       | 90 m                                 |                      |            |
| Pump Head             | 0 m                                  | Pump Flow Rate       | 1.24 m3/hr |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 0 kW       |
| Casing Pressure       | 0 kPa                                |                      |            |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 10.06 m    |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 67                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 81.5 m                               | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 23.28 m                              | Int.(Gauge) Pressure | 228.27 kPa |
| Total Node Head  | 104.78 m                             |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |                 |                      |           |
|------------------|-----------------|----------------------|-----------|
| Node No          | 69              | Node Type            | Junction  |
| Description      | Old CV Crossing | Equipment No         |           |
| Rel. Level (RL)  | 102 m           | Pressure Input       | 0 kPa     |
| Nozzle K value   | -               | Ext Flow (+In/-Out)  | 0 m3/hr   |
| Int.(Gauge) Head | 1.03 m          | Int.(Gauge) Pressure | 10.12 kPa |
| Total Node Head  | 103.03 m        |                      |           |

**Bateman Engineering**

|                       |                                      |                      |                    |
|-----------------------|--------------------------------------|----------------------|--------------------|
| Project               | Water Supply Review                  | Client               | MMICCL Ltd         |
| Project No.           |                                      | Design Date          | 23/01/2016         |
| Category              | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa         |
| Description           | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |                    |
| Node No               | 74                                   | Node Type            | Pump               |
| Description           | Stormwater Pond Pump                 | Equipment No         | Grundfoss SP160-2N |
| Rel. Level (RL)       | 92 m                                 | Pressure Input       | 0 kPa              |
| Nozzle K value        | -                                    | Ext Flow (+In/-Out)  | -                  |
| Int.(Gauge) Head      | -                                    | Int.(Gauge) Pressure | -                  |
| Total Node Head       | 118.82 m                             |                      |                    |
| Pump Head             | 27.5 m                               | Pump Flow Rate       | 148.03 m3/hr       |
| Pump / Fan Efficiency | 70 %                                 | Pump Absorbed Power  | 15.84 kW           |
| Casing Pressure       | 263 kPa                              |                      |                    |
| Pump NPSH required    | 0 m                                  | Pump NPSH available  | 9.37 m             |



**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 76                                   | Node Type            | Junction   |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 100 m                                | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | 0 m3/hr    |
| Int.(Gauge) Head | 95.56 m                              | Int.(Gauge) Pressure | 937.08 kPa |
| Total Node Head  | 195.56 m                             |                      |            |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 80                                   | Node Type            | Tank       |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 73.5 m                               | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -          |
| Int.(Gauge) Head | -                                    | Int.(Gauge) Pressure | -          |
| Total Node Head  | 73.5 m                               |                      |            |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 83                                   | Node Type            | Tank       |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | -5 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -          |
| Int.(Gauge) Head | -                                    | Int.(Gauge) Pressure | -          |
| Total Node Head  | -5 m                                 |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |      |                      |       |
|------------------|------|----------------------|-------|
| Node No          | 85   | Node Type            | Tank  |
| Description      |      | Equipment No         |       |
| Rel. Level (RL)  | 95 m | Pressure Input       | 0 kPa |
| Nozzle K value   | -    | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -    | Int.(Gauge) Pressure | -     |
| Total Node Head  | 95 m |                      |       |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 87                                   | Node Type            | Tank       |
| Description      |                                      | Equipment No         |            |
| Rel. Level (RL)  | 95 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -          |
| Int.(Gauge) Head | -                                    | Int.(Gauge) Pressure | -          |
| Total Node Head  | 95 m                                 |                      |            |

**Bateman Engineering**

|             |                                      |              |            |
|-------------|--------------------------------------|--------------|------------|
| Project     | Water Supply Review                  | Client       | MMICCL Ltd |
| Project No. |                                      | Design Date  | 23/01/2016 |
| Category    | Demo Liquid Mine Water System        | Atmos. Press | 100.21 kPa |
| Description | MICCL Water Supply PS1-PS3 Upgrade 2 |              |            |

|                  |      |                      |       |
|------------------|------|----------------------|-------|
| Node No          | 89   | Node Type            | Tank  |
| Description      |      | Equipment No         |       |
| Rel. Level (RL)  | 92 m | Pressure Input       | 0 kPa |
| Nozzle K value   | -    | Ext Flow (+In/-Out)  | -     |
| Int.(Gauge) Head | -    | Int.(Gauge) Pressure | -     |
| Total Node Head  | 92 m |                      |       |

**Bateman Engineering**

|                  |                                      |                      |            |
|------------------|--------------------------------------|----------------------|------------|
| Project          | Water Supply Review                  | Client               | MMICCL Ltd |
| Project No.      |                                      | Design Date          | 23/01/2016 |
| Category         | Demo Liquid Mine Water System        | Atmos. Press         | 100.21 kPa |
| Description      | MICCL Water Supply PS1-PS3 Upgrade 2 |                      |            |
| Node No          | 91                                   | Node Type            | Tank       |
| Description      | Pit Transfer Pond                    | Equipment No         |            |
| Rel. Level (RL)  | 70 m                                 | Pressure Input       | 0 kPa      |
| Nozzle K value   | -                                    | Ext Flow (+In/-Out)  | -          |
| Int.(Gauge) Head | -                                    | Int.(Gauge) Pressure | -          |
| Total Node Head  | 70 m                                 |                      |            |